CONSENT MONITORING REPORT



your Community Partner

Consent Name | Te Kauwhata Wastewater Treatment

System

Consent No. 940355

Year 1 July 2011 – 30 June 2012

Date 28 September 2012 File No. USV03 / 55 06 19M District Office 15 Galileo St, Private Bag 544 Ngaruawahia New Zealand Ph 07 824 8633 Fax 07 824 8091 Call Free 0800 492 452 www.waikatodistict.govt.nz

Te Kauwhata Wastewater Treatment System 1 July 2011 – 30 June 2012

The Waikato District Council holds resource consent 940355 to discharge up to 1080 cubic metres of treated wastewater per day from the Te Kauwhata wastewater treatment plant to Lake Waikare. The consent expired on 30 July 2008. A replacement consent has been applied for.

A review of the consent conditions during the 2011-2012 reporting year indicated that the treatment system is meeting the water quality parameters of the resource consent and is having no more than a minor environmental effect.

Discharge water quality parameters generally remained the same as the previous reporting period.

The maximum consented discharge flow was exceeded regularly during periods of heavy rainfall.

The maximum daily flow was 1853 cubic metres per day 15 July 2011. This corresponded to a major rainfall event. The average was 656 cubic metres per day over the total reporting period. This shows that infiltration is still a major problem and will require ongoing work. We have budgeted a project to address this in 2012/2013.

The overall performance of the treatment plant has remained excellent.

P Saward R Bax
TREATMENT PLANTS ENGINEER GENERAL MANAGER
WATER & FACILITIES