

LFG – Liquid fuels and gas

The rules in the LFG – Liquid fuels and gas chapter only apply to facilities and structures operated by a network utility operator.

Rules

LFG-R1	Below ground pipelines for the conveyance of liquid fuels and gas	
All zones	<p>(1) Activity status: PER</p> <p>Activity-specific standards:</p> <p>(a) Below ground pipelines for the conveyance of liquid fuels and gas that comply with all of the following:</p> <p>(i) Any aboveground sections of pipeline must comply with the following:</p> <p>(1) Not exceed 25m in length, and</p> <p>(2) Not exceed 300mm in diameter.</p> <p>(ii) Gas pipelines must not exceed a gauge pressure of 2,000 kilopascals; and</p> <p>(iii) Is not located within an Identified Area.</p>	<p>(2) Activity status where compliance not achieved: DIS</p>
LFG-R2	Below ground pipelines located within an Identified Area	
All zones	<p>(1) Activity status: PER</p> <p>Activity-specific standards:</p> <p>(a) Below ground pipelines for the conveyance of liquid fuels and gas, located within an Identified Area that comply with the following:</p> <p>(i) There are no aboveground sections of pipeline within the Identified Area; and</p> <p>(ii) Gas pipelines must not exceed a gauge pressure of 2,000 kilopascals.</p>	<p>(2) Activity status where compliance not achieved: DIS</p>
LFG-R3	Storage facilities and pump stations for liquid fuels and gas	
All zones	<p>(1) Activity status: PER</p> <p>Activity-specific standards:</p> <p>(a) Storage facilities and pump stations for liquid fuels and gas that comply with all of the following:</p> <p>(i) Is not located within an Identified Area; and</p>	<p>(2) Activity status where compliance not achieved: DIS</p>

	(ii) Is not located on a road, or unformed road.	
--	--	--

Appeals Version